

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 4/26/2024	MGD	Report Only	1.51
Average	MGD	Report Only	3.41
Maximum , 4/3/2024	MGD	Report Only	7.99
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	5.1
Required samples	per week	2	
Average Loading	lb/day	1334	130.1
Required samples Loading	per week	2	
Maximum , 4/8/2024	MG/L	50.0	7.1
Required samples	per week	2	
Maximum Loading	lb/day	2669	295.7
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	7
Required samples	per week	2	
Average Loading	lb/day	1601	232
Required samples Loading	per week	2	
Maximum , 4/14/2024	MG/L	60	11
Required samples	per week	2	
Maximum Loading	lb/day	3202	544
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	9.2
Required samples	per week	2	
Average Loading	lb/day	801	185
Required samples Loading	per week	2	
Maximum , 4/21/2024	MG/L	30.0	16.0
Required samples	per week	2	
Maximum Loading	lb/day	1601	254
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	41
Required samples	per week	2	
Maximum , 4/3/2024	#/100ML	400	59
Required samples	per week	2	
planteff - plant effency			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 4/1/2024	%	85	92.0
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	98.2
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 4/2/2024	S.U.	6.0	6.60
Maximum , 4/23/2024	S.U.	9	7.20
Required samples	per week	2	