

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

| Location/Parameter | Units | Limit | Actual |
|--|-----------|-------------|--------|
| FNLEFF - FINAL EFFLUENT SAMPLE | | | |
| Flow Mgd - Flow Thru Treatment Plant Mgd | | | |
| Minimum , 8/11/2023 | MGD | Report Only | 1.24 |
| Average | MGD | Report Only | 1.90 |
| Maximum , 8/14/2023 | MGD | Report Only | 4.20 |
| FNLEFF - FINAL EFFLUENT SAMPLE | | | |
| CARB BOD 5 DAY - 80126 | | | |
| Average | MG/L | 25.0 | 3.5 |
| Required samples | per week | 2 | |
| Average Loading | lb/day | 1334 | 54.2 |
| Required samples Loading | per week | 2 | |
| Maximum , 8/21/2023 | MG/L | 50.0 | 4.1 |
| Required samples | per week | 2 | |
| Maximum Loading | lb/day | 2669 | 101.7 |
| Required samples Loading | per week | 2 | |
| FNLEFF - FINAL EFFLUENT SAMPLE | | | |
| Solids TSS - Total Suspended Solids TSS | | | |
| Average | MG/L | 30 | 14 |
| Required samples | per week | 2 | |
| Average Loading | lb/day | 1601 | 231 |
| Required samples Loading | per week | 2 | |
| Maximum , 8/6/2023 | MG/L | 60 | 20 |
| Required samples | per week | 2 | |
| Maximum Loading | lb/day | 3202 | 526 |
| Required samples Loading | per week | 2 | |
| FINAL EFFLUENT SAMPLE | | | |
| Total Nitrogen Ammonia | | | |
| Average | MG/L | 15.0 | <1.7 |
| Required samples | per week | 2 | |
| Average Loading | lb/day | 801 | <23 |
| Required samples Loading | per week | 2 | |
| Maximum , 8/28/2023 | MG/L | 30.0 | 4.5 |
| Required samples | per week | 2 | |
| Maximum Loading | lb/day | 1601 | 56 |
| Required samples Loading | per week | 2 | |
| FINAL EFFLUENT SAMPLE | | | |
| Fecal Coliform Bacteria | | | |
| Average | #/100ML | 200 | 23 |
| Required samples | per week | 2 | |
| Maximum , 8/16/2023 | #/100ML | 400 | 156 |
| Required samples | per week | 2 | |
| planteff - plant efficiency | | | |
| ~PCARB BOD 5 DAY - % Rem 80126 | | | |
| Minimum , 8/15/2023 | % | 85 | 87.9 |
| Required samples | per month | 4 | |
| FINAL EFFLUENT SAMPLE | | | |
| TSS % Removal | | | |
| Minimum | % | 85 | 96.4 |
| Required samples | per month | 4 | |
| FINAL EFFLUENT SAMPLE | | | |
| pH | | | |
| Minimum , 8/20/2023 | S.U. | 6.0 | 6.20 |
| Maximum , 8/7/2023 | S.U. | 9 | 6.51 |
| Required samples | per week | 2 | |