

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 8/23/2024	MGD	Report Only	0.86
Average	MGD	Report Only	1.06
Maximum	MGD	Report Only	2.57
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	4.9
Required samples	per week	2	
Average Loading	lb/day	1334	41.9
Required samples Loading	per week	2	
Maximum , 8/12/2024	MG/L	50.0	9.6
Required samples	per week	2	
Maximum Loading	lb/day	2669	84.4
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	13
Required samples	per week	2	
Average Loading	lb/day	1601	113
Required samples Loading	per week	2	
Maximum , 8/12/2024	MG/L	60	39
Required samples	per week	2	
Maximum Loading	lb/day	3202	342
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	<1.5
Required samples	per week	2	
Average Loading	lb/day	801	<12
Required samples Loading	per week	2	
Maximum , 8/18/2024	MG/L	30.0	4.1
Required samples	per week	2	
Maximum Loading	lb/day	1601	34
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	8
Required samples	per week	2	
Maximum , 8/12/2024	#/100ML	400	58
Required samples	per week	2	
planteff - plant effency			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 8/12/2024	%	85	92.5
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	96.4
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 8/27/2024	S.U.	6.0	6.79
Maximum , 8/19/2024	S.U.	9	6.99
Required samples	per week	2	