

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 2/15/2023	MGD	Report Only	1.48
Average	MGD	Report Only	1.83
Maximum , 2/27/2023	MGD	Report Only	2.43
FNLEFF - FINAL EFFLUENT SAMPLE			
BOD 5 - CBOD 5 Day 20 Deg C			
Average	MG/L	25.0	5.4
Required samples	per week	2	
Average Loading	lb/day	1334	83
Required samples Loading	per week	2	
Maximum	MG/L	50.0	8.4
Required samples	per week	2	
Maximum Loading	lb/day	2669	137
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	10
Required samples	per week	2	
Average Loading	lb/day	1601	154
Required samples Loading	per week	2	
Maximum , 2/22/2023	MG/L	60	17
Required samples	per week	2	
Maximum Loading	lb/day	3202	309
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	10.4
Required samples	per week	2	
Average Loading	lb/day	801	161
Required samples Loading	per week	2	
Maximum , 2/7/2023	MG/L	30.0	14.2
Required samples	per week	2	
Maximum Loading	lb/day	1601	214
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	12
Required samples	per week	2	
Maximum , 2/22/2023	#/100ML	400	57
Required samples	per week	2	
FINAL EFFLUENT SAMPLE			
BOD % Removal			
Minimum	%	85	96.3
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	96.6
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 2/27/2023	S.U.	6.0	6.62
Maximum , 2/7/2023	S.U.	9	6.94
Required samples	per week	2	