

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 2/4/2024	MGD	Report Only	1.30
Average	MGD	Report Only	1.73
Maximum , 2/28/2024	MGD	Report Only	3.29
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	7.0
Required samples	per week	2	
Average Loading	lb/day	1334	89.0
Required samples Loading	per week	2	
Maximum , 2/19/2024	MG/L	50.0	10.5
Required samples	per week	2	
Maximum Loading	lb/day	2669	136.5
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	10
Required samples	per week	2	
Average Loading	lb/day	1601	127
Required samples Loading	per week	2	
Maximum , 2/20/2024	MG/L	60	19
Required samples	per week	2	
Maximum Loading	lb/day	3202	226
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	13.9
Required samples	per week	2	
Average Loading	lb/day	801	180
Required samples Loading	per week	2	
Maximum , 2/21/2024	MG/L	30.0	21.1
Required samples	per week	2	
Maximum Loading	lb/day	1601	264
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	27
Required samples	per week	2	
Maximum , 2/27/2024	#/100ML	400	69
Required samples	per week	2	
planteff - plant effency			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 2/19/2024	%	85	94.3
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	97.5
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 2/26/2024	S.U.	6.0	6.73
Maximum , 2/6/2024	S.U.	9	7.20
Required samples	per week	2	