

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 2/4/2025	MGD	Report Only	1.46
Average	MGD	Report Only	2.34
Maximum , 2/15/2025	MGD	Report Only	4.70
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	3.3
Required samples	per week	2	
Average Loading	lb/day	1334	60.9
Required samples Loading	per week	2	
Maximum , 2/18/2025	MG/L	50.0	3.9
Required samples	per week	2	
Maximum Loading	lb/day	2669	101.1
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	3
Required samples	per week	2	
Average Loading	lb/day	1601	55
Required samples Loading	per week	2	
Maximum , 2/4/2025	MG/L	60	7
Required samples	per week	2	
Maximum Loading	lb/day	3202	85
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	8.1
Required samples	per week	2	
Average Loading	lb/day	801	137
Required samples Loading	per week	2	
Maximum , 2/3/2025	MG/L	30.0	13.1
Required samples	per week	2	
Maximum Loading	lb/day	1601	246
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	<2
Required samples	per week	2	
Maximum , 2/19/2025	#/100ML	400	7
Required samples	per week	2	
planteff - plant effency			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 2/17/2025	%	85	95.8
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	98.9
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 2/18/2025	S.U.	6.0	6.71
Maximum , 2/4/2025	S.U.	9	7.14
Required samples	per week	2	