

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 1/5/2024	MGD	Report Only	1.51
Average	MGD	Report Only	2.86
Maximum , 1/28/2024	MGD	Report Only	7.47
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	<4.5
Required samples	per week	2	
Average Loading	lb/day	1334	<109.1
Required samples Loading	per week	2	
Maximum , 1/10/2024	MG/L	50.0	7.5
Required samples	per week	2	
Maximum Loading	lb/day	2669	257.3
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	5
Required samples	per week	2	
Average Loading	lb/day	1601	121
Required samples Loading	per week	2	
Maximum , 1/23/2024	MG/L	60	10
Required samples	per week	2	
Maximum Loading	lb/day	3202	376
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	5.4
Required samples	per week	2	
Average Loading	lb/day	801	105
Required samples Loading	per week	2	
Maximum , 1/23/2024	MG/L	30.0	10.6
Required samples	per week	2	
Maximum Loading	lb/day	1601	260
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	19
Required samples	per week	2	
Maximum , 1/30/2024	#/100ML	400	66
Required samples	per week	2	
planteff - plant effency			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 1/10/2024	%	85	90.6
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	98.2
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 1/8/2024	S.U.	6.0	6.82
Maximum , 1/9/2024	S.U.	9	7.15
Required samples	per week	2	