

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 1/8/2025	MGD	Report Only	1.36
Average	MGD	Report Only	1.55
Maximum	MGD	Report Only	2.45
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	3.4
Required samples	per week	2	
Average Loading	lb/day	1334	43.6
Required samples Loading	per week	2	
Maximum , 1/20/2025	MG/L	50.0	4.3
Required samples	per week	2	
Maximum Loading	lb/day	2669	56.6
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	4
Required samples	per week	2	
Average Loading	lb/day	1601	44
Required samples Loading	per week	2	
Maximum , 1/20/2025	MG/L	60	6
Required samples	per week	2	
Maximum Loading	lb/day	3202	80
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	3.7
Required samples	per week	2	
Average Loading	lb/day	801	48
Required samples Loading	per week	2	
Maximum , 1/28/2025	MG/L	30.0	9.1
Required samples	per week	2	
Maximum Loading	lb/day	1601	117
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	<1
Required samples	per week	2	
Maximum , 1/13/2025	#/100ML	400	3
Required samples	per week	2	
planteff - plant effencicy			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 1/20/2025	%	85	94.0
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	99.0
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 1/7/2025	S.U.	6.0	6.56
Maximum , 1/28/2025	S.U.	9	6.86
Required samples	per week	2	