

Limit Summary: ( \*\* designates values exceeding limit )  
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 7/11/2023	MGD	Report Only	1.27
Average	MGD	Report Only	1.58
Maximum , 7/29/2023	MGD	Report Only	3.47
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	3.3
Required samples	per week	2	
Average Loading	lb/day	1334	40.2
Required samples Loading	per week	2	
Maximum , 7/18/2023	MG/L	50.0	5.6
Required samples	per week	2	
Maximum Loading	lb/day	2669	69.6
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	9
Required samples	per week	2	
Average Loading	lb/day	1601	118
Required samples Loading	per week	2	
Maximum , 7/24/2023	MG/L	60	21
Required samples	per week	2	
Maximum Loading	lb/day	3202	281
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	2.0
Required samples	per week	2	
Average Loading	lb/day	801	24
Required samples Loading	per week	2	
Maximum , 7/7/2023	MG/L	30.0	4.9
Required samples	per week	2	
Maximum Loading	lb/day	1601	57
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	30
Required samples	per week	2	
Maximum , 7/19/2023	#/100ML	400	102
Required samples	per week	2	
planteff - plant effency			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 7/17/2023	%	85	92.6
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	97.7
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 7/6/2023	S.U.	6.0	6.28
Maximum , 7/30/2023	S.U.	9	6.45
Required samples	per week	2	