

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 7/19/2024	MGD	Report Only	0.93
Average	MGD	Report Only	1.23
Maximum , 7/29/2024	MGD	Report Only	1.92
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	<7.4
Required samples	per week	2	
Average Loading	lb/day	1334	<80.8
Required samples Loading	per week	2	
Maximum , 7/9/2024	MG/L	50.0	27.2
Required samples	per week	2	
Maximum Loading	lb/day	2669	283.6
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	9
Required samples	per week	2	
Average Loading	lb/day	1601	104
Required samples Loading	per week	2	
Maximum , 7/21/2024	MG/L	60	24
Required samples	per week	2	
Maximum Loading	lb/day	3202	245
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	<1.5
Required samples	per week	2	
Average Loading	lb/day	801	<14
Required samples Loading	per week	2	
Maximum , 7/23/2024	MG/L	30.0	3.2
Required samples	per week	2	
Maximum Loading	lb/day	1601	29
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	8
Required samples	per week	2	
Maximum , 7/2/2024	#/100ML	400	61
Required samples	per week	2	
planteff - plant effency			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 7/15/2024	%	85	90.9
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	98.0
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 7/2/2024	S.U.	6.0	6.86
Maximum , 7/30/2024	S.U.	9	7.10
Required samples	per week	2	