

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 6/13/2024	MGD	Report Only	1.25
Average	MGD	Report Only	1.49
Maximum , 6/23/2024	MGD	Report Only	2.06
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	3.1
Required samples	per week	2	
Average Loading	lb/day	1334	38.4
Required samples Loading	per week	2	
Maximum , 6/24/2024	MG/L	50.0	4.2
Required samples	per week	2	
Maximum Loading	lb/day	2669	56.3
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	5
Required samples	per week	2	
Average Loading	lb/day	1601	68
Required samples Loading	per week	2	
Maximum , 6/23/2024	MG/L	60	8
Required samples	per week	2	
Maximum Loading	lb/day	3202	138
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	<2.1
Required samples	per week	2	
Average Loading	lb/day	801	<29
Required samples Loading	per week	2	
Maximum , 6/23/2024	MG/L	30.0	4.7
Required samples	per week	2	
Maximum Loading	lb/day	1601	81
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	9
Required samples	per week	2	
Maximum , 6/24/2024	#/100ML	400	51
Required samples	per week	2	
planteff - plant effency			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 6/24/2024	%	85	95.9
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	99.2
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 6/4/2024	S.U.	6.0	6.78
Maximum , 6/18/2024	S.U.	9	7.08
Required samples	per week	2	