

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 3/20/2023	MGD	Report Only	1.38
Average	MGD	Report Only	2.01
Maximum , 3/24/2023	MGD	Report Only	4.45
FNLEFF - FINAL EFFLUENT SAMPLE			
BOD 5 - CBOD 5 Day 20 Deg C			
Average	MG/L	25.0	4.2
Required samples	per week	2	
Average Loading	lb/day	1334	59
Required samples Loading	per week	2	
Maximum , 3/7/2023	MG/L	50.0	5.2
Required samples	per week	2	
Maximum Loading	lb/day	2669	79
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	8
Required samples	per week	2	
Average Loading	lb/day	1601	109
Required samples Loading	per week	2	
Maximum , 3/13/2023	MG/L	60	12
Required samples	per week	2	
Maximum Loading	lb/day	3202	171
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	7.1
Required samples	per week	2	
Average Loading	lb/day	801	117
Required samples Loading	per week	2	
Maximum , 3/14/2023	MG/L	30.0	11.6
Required samples	per week	2	
Maximum Loading	lb/day	1601	224
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	15
Required samples	per week	2	
Maximum , 3/20/2023	#/100ML	400	59
Required samples	per week	2	
FINAL EFFLUENT SAMPLE			
BOD % Removal			
Minimum	%	85	97.0
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	96.9
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 3/20/2023	S.U.	6.0	6.47
Maximum , 3/7/2023	S.U.	9	6.75
Required samples	per week	2	