

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 3/11/2024	MGD	Report Only	0.54
Average	MGD	Report Only	2.12
Maximum , 3/26/2024	MGD	Report Only	3.42
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	4.9
Required samples	per week	2	
Average Loading	lb/day	1334	81.3
Required samples Loading	per week	2	
Maximum , 3/5/2024	MG/L	50.0	7.3
Required samples	per week	2	
Maximum Loading	lb/day	2669	195.1
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	5
Required samples	per week	2	
Average Loading	lb/day	1601	67
Required samples Loading	per week	2	
Maximum , 3/4/2024	MG/L	60	7
Required samples	per week	2	
Maximum Loading	lb/day	3202	120
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	<3.6
Required samples	per week	2	
Average Loading	lb/day	801	<69
Required samples Loading	per week	2	
Maximum , 3/4/2024	MG/L	30.0	7.0
Required samples	per week	2	
Maximum Loading	lb/day	1601	168
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	<18
Required samples	per week	2	
Maximum , 3/4/2024	#/100ML	400	67
Required samples	per week	2	
planteff - plant effency			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 3/5/2024	%	85	95.5
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	98.2
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 3/26/2024	S.U.	6.0	6.53
Maximum , 3/11/2024	S.U.	9	6.90
Required samples	per week	2	