

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 3/4/2025	MGD	Report Only	1.15
Average	MGD	Report Only	1.58
Maximum , 3/30/2025	MGD	Report Only	2.86
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	3.7
Required samples	per week	2	
Average Loading	lb/day	1334	49.8
Required samples Loading	per week	2	
Maximum , 3/24/2025	MG/L	50.0	5.6
Required samples	per week	2	
Maximum Loading	lb/day	2669	94.9
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	4
Required samples	per week	2	
Average Loading	lb/day	1601	71
Required samples Loading	per week	2	
Maximum , 3/23/2025	MG/L	60	10
Required samples	per week	2	
Maximum Loading	lb/day	3202	202
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	8.9
Required samples	per week	2	
Average Loading	lb/day	801	130
Required samples Loading	per week	2	
Maximum , 3/30/2025	MG/L	30.0	12.9
Required samples	per week	2	
Maximum Loading	lb/day	1601	307
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	3
Required samples	per week	2	
Maximum , 3/24/2025	#/100ML	400	150
Required samples	per week	2	
planteff - plant effency			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 3/24/2025	%	85	96.2
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	99.2
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 3/3/2025	S.U.	6.0	6.74
Maximum	S.U.	9	7.01
Required samples	per week	2	