

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 5/28/2023	MGD	Report Only	1.34
Average	MGD	Report Only	1.84
Maximum , 5/2/2023	MGD	Report Only	2.78
FNLEFF - FINAL EFFLUENT SAMPLE			
BOD 5 - CBOD 5 Day 20 Deg C			
Average	MG/L	25.0	<4.6
Required samples	per week	2	
Average Loading	lb/day	1334	<75
Required samples Loading	per week	2	
Maximum , 5/2/2023	MG/L	50.0	6.2
Required samples	per week	2	
Maximum Loading	lb/day	2669	143
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	8
Required samples	per week	2	
Average Loading	lb/day	1601	129
Required samples Loading	per week	2	
Maximum , 5/9/2023	MG/L	60	17
Required samples	per week	2	
Maximum Loading	lb/day	3202	271
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	4.2
Required samples	per week	2	
Average Loading	lb/day	801	61
Required samples Loading	per week	2	
Maximum , 5/22/2023	MG/L	30.0	9.4
Required samples	per week	2	
Maximum Loading	lb/day	1601	134
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	17
Required samples	per week	2	
Maximum , 5/2/2023	#/100ML	400	59
Required samples	per week	2	
FINAL EFFLUENT SAMPLE			
BOD % Removal			
Minimum	%	85	>96.8
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	97.1
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 5/3/2023	S.U.	6.0	6.37
Maximum , 5/23/2023	S.U.	9	6.66
Required samples	per week	2	