

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 5/24/2024	MGD	Report Only	1.41
Average	MGD	Report Only	1.72
Maximum , 5/5/2024	MGD	Report Only	2.36
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	<2.7
Required samples	per week	2	
Average Loading	lb/day	1334	<38.8
Required samples Loading	per week	2	
Maximum , 5/7/2024	MG/L	50.0	3.1
Required samples	per week	2	
Maximum Loading	lb/day	2669	44.3
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	3
Required samples	per week	2	
Average Loading	lb/day	1601	38
Required samples Loading	per week	2	
Maximum , 5/12/2024	MG/L	60	5
Required samples	per week	2	
Maximum Loading	lb/day	3202	80
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	<1.1
Required samples	per week	2	
Average Loading	lb/day	801	<16
Required samples Loading	per week	2	
Maximum , 5/5/2024	MG/L	30.0	<1.1
Required samples	per week	2	
Maximum Loading	lb/day	1601	<22
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	5
Required samples	per week	2	
Maximum , 5/28/2024	#/100ML	400	49
Required samples	per week	2	
planteff - plant effency			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 5/7/2024	%	85	97.8
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	99.4
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 5/14/2024	S.U.	6.0	6.64
Maximum , 5/20/2024	S.U.	9	6.82
Required samples	per week	2	