

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 11/7/2023	MGD	Report Only	1.20
Average	MGD	Report Only	1.54
Maximum , 11/21/2023	MGD	Report Only	3.89
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	<4.6
Required samples	per week	2	
Average Loading	lb/day	1334	<52.0
Required samples Loading	per week	2	
Maximum	MG/L	50.0	6.7
Required samples	per week	2	
Maximum Loading	lb/day	2669	80.2
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	5
Required samples	per week	2	
Average Loading	lb/day	1601	56
Required samples Loading	per week	2	
Maximum	MG/L	60	12
Required samples	per week	2	
Maximum Loading	lb/day	3202	143
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	7.4
Required samples	per week	2	
Average Loading	lb/day	801	118
Required samples Loading	per week	2	
Maximum , 11/7/2023	MG/L	30.0	14.2
Required samples	per week	2	
Maximum Loading	lb/day	1601	331
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	12
Required samples	per week	2	
Maximum , 11/21/2023	#/100ML	400	57
Required samples	per week	2	
planteff - plant effency			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 11/7/2023	%	85	91.6
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	98.6
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 11/20/2023	S.U.	6.0	6.03
Maximum , 11/6/2023	S.U.	9	6.73
Required samples	per week	2	