

Limit Summary: ( \*\* designates values exceeding limit )  
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
<b>FNLEFF - FINAL EFFLUENT SAMPLE</b>			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 10/4/2023	MGD	Report Only	0.91
Average	MGD	Report Only	1.32
Maximum , 10/30/2023	MGD	Report Only	2.76
<b>FNLEFF - FINAL EFFLUENT SAMPLE</b>			
<b>CARB BOD 5 DAY - 80126</b>			
Average	MG/L	25.0	4.0
Required samples	per week	2	
Average Loading	lb/day	1334	43.4
Required samples Loading	per week	2	
Maximum , 10/2/2023	MG/L	50.0	6.5
Required samples	per week	2	
Maximum Loading	lb/day	2669	90.4
Required samples Loading	per week	2	
<b>FNLEFF - FINAL EFFLUENT SAMPLE</b>			
<b>Solids TSS - Total Suspended Solids TSS</b>			
Average	MG/L	30	15
Required samples	per week	2	
Average Loading	lb/day	1601	173
Required samples Loading	per week	2	
Maximum , 10/3/2023	MG/L	60	28
Required samples	per week	2	
Maximum Loading	lb/day	3202	506
Required samples Loading	per week	2	
<b>FINAL EFFLUENT SAMPLE</b>			
<b>Total Nitrogen Ammonia</b>			
Average	MG/L	15.0	3.8
Required samples	per week	2	
Average Loading	lb/day	801	50
Required samples Loading	per week	2	
Maximum , 10/29/2023	MG/L	30.0	8.4
Required samples	per week	2	
Maximum Loading	lb/day	1601	186
Required samples Loading	per week	2	
<b>FINAL EFFLUENT SAMPLE</b>			
<b>Fecal Coliform Bacteria</b>			
Average	#/100ML	200	24
Required samples	per week	2	
Maximum , 10/3/2023	#/100ML	400	64
Required samples	per week	2	
<b>planteff - plant efficiency</b>			
<b>~PCARB BOD 5 DAY - % Rem 80126</b>			
Minimum , 10/3/2023	%	85	92.8
Required samples	per month	4	
<b>FINAL EFFLUENT SAMPLE</b>			
<b>TSS % Removal</b>			
Minimum	%	85	96.9
Required samples	per month	4	
<b>FINAL EFFLUENT SAMPLE</b>			
<b>pH</b>			
Minimum , 10/16/2023	S.U.	6.0	6.10
Maximum , 10/2/2023	S.U.	9	6.54
Required samples	per week	2	