

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum	MGD	Report Only	1.01
Average	MGD	Report Only	1.23
Maximum , 9/7/2023	MGD	Report Only	1.62
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	4.0
Required samples	per week	2	
Average Loading	lb/day	1334	40.7
Required samples Loading	per week	2	
Maximum , 9/26/2023	MG/L	50.0	6.8
Required samples	per week	2	
Maximum Loading	lb/day	2669	67.0
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	19
Required samples	per week	2	
Average Loading	lb/day	1601	200
Required samples Loading	per week	2	
Maximum , 9/10/2023	MG/L	60	42
Required samples	per week	2	
Maximum Loading	lb/day	3202	468
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	<3.2
Required samples	per week	2	
Average Loading	lb/day	801	<32
Required samples Loading	per week	2	
Maximum , 9/27/2023	MG/L	30.0	11.3
Required samples	per week	2	
Maximum Loading	lb/day	1601	108
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	36
Required samples	per week	2	
Maximum , 9/13/2023	#/100ML	400	57
Required samples	per week	2	
planteff - plant efficiency			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 9/5/2023	%	85	94.3
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	95.9
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 9/10/2023	S.U.	6.0	6.10
Maximum , 9/26/2023	S.U.	9	6.59
Required samples	per week	2	