

Limit Summary: (** designates values exceeding limit)
0 values exceeding limit.

Location/Parameter	Units	Limit	Actual
FNLEFF - FINAL EFFLUENT SAMPLE			
Flow Mgd - Flow Thru Treatment Plant Mgd			
Minimum , 9/17/2024	MGD	Report Only	0.91
Average	MGD	Report Only	1.09
Maximum , 9/6/2024	MGD	Report Only	1.93
FNLEFF - FINAL EFFLUENT SAMPLE			
CARB BOD 5 DAY - 80126			
Average	MG/L	25.0	6.2
Required samples	per week	2	
Average Loading	lb/day	1334	50.5
Required samples Loading	per week	2	
Maximum , 9/24/2024	MG/L	50.0	9.9
Required samples	per week	2	
Maximum Loading	lb/day	2669	76.6
Required samples Loading	per week	2	
FNLEFF - FINAL EFFLUENT SAMPLE			
Solids TSS - Total Suspended Solids TSS			
Average	MG/L	30	11
Required samples	per week	2	
Average Loading	lb/day	1601	90
Required samples Loading	per week	2	
Maximum , 9/22/2024	MG/L	60	33
Required samples	per week	2	
Maximum Loading	lb/day	3202	272
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Total Nitrogen Ammonia			
Average	MG/L	15.0	<3.0
Required samples	per week	2	
Average Loading	lb/day	801	<26
Required samples Loading	per week	2	
Maximum , 9/10/2024	MG/L	30.0	11.6
Required samples	per week	2	
Maximum Loading	lb/day	1601	102
Required samples Loading	per week	2	
FINAL EFFLUENT SAMPLE			
Fecal Coliform Bacteria			
Average	#/100ML	200	24
Required samples	per week	2	
Maximum , 9/18/2024	#/100ML	400	84
Required samples	per week	2	
planteff - plant efficiency			
~PCARB BOD 5 DAY - % Rem 80126			
Minimum , 9/23/2024	%	85	92.9
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
TSS % Removal			
Minimum	%	85	97.1
Required samples	per month	4	
FINAL EFFLUENT SAMPLE			
pH			
Minimum , 9/13/2024	S.U.	6.0	6.59
Maximum , 9/10/2024	S.U.	9	7.23
Required samples	per week	2	